Thomas@Betts



Representative

Catalog Number: S203-K50 UPC Number: 66201917173

Status: Active

Miniature Circuit Breaker, Supplementary Protector, Rated Current 50 Amps, 3 Pole, Interrupt Rating 6 kA, Thermal Magnetic Trip Curve K, Voltage up to 277/Y480 VAC, DIN Rail Mounted, Finger Safe and Multi-Function Terminals, UL 1077, CSA 22.2 No. 235

| North American Specifications (UNSPSC) | |
|--|--|
| UNSPSC | 39121603 Miniature circuit breakers |
| IGCC | 4897 Miniature circuit breakers |
| Brand Name | ABB |
| Туре | High Performance MCB Provides Compact Supple mentary, Energy Limiting, Circuit Protection |
| Special Features | DIN Rail Mounting, Finger Safe and Multi-Function Terminals |
| Application | Designed for Allowing Higher In-Rush Current Dur- ing System Start Up; Example: Motors, Transform- ers |
| Standard | UL 1077, CSA 22.2 No. 235, IEC 60898 |
| Voltage Rating | 277/Y480 VAC |
| Amperage Rating | 50 Amps |
| Frequency Rating | 50/60 Hertz |
| Trip Type | K |
| Interrupt Rating | 6 kA |
| Number Of Poles | 3 |
| Auxiliary Contacts | Yes |
| Length | 69 mm |
| Width | 52.5 mm |
| Height | 88 mm |
| Operating Temperature | -25 to +55 Degrees Celcius |
| Packaging | |
| Outer Quantity | 1 |
| Outer Dimensions (inches) | 2.28x3.62x3.15 |
| Weight Uom | 1.01 lbs. Each |

Documents / Support Tools

Technical Drawing / Data Sheet Canada Available on Website

For further technical assistance, please contact us...

T&B Technical Support MS 3B-50

860 Ridge Lake Blvd. Memphis, TN 38120 Hours: 7AM - 6PM CDT Monday-Friday Phone: (888) 862-3289 Fax: (901) 252-1321 Email:techsupport@tnb.com

Thomas & Betts - USA 860 Ridge Lake Blvd. Memphis, TN 38120 www.tnb.com